



Service Quote

Date: February 5, 2016

Quote No. G8801691

Expiration: February 25, 2016

To: A & W Restaurant
10153 King George Blvd
Tel: (604) 588-5271

Account Rep.	Site Location	Payment Terms	Due Date	Start Time	Site contact
Alex Collins	A & W Central City	Net 30	ASAP	TBD	Terry Mclean

Canopies	Fans	Runs	Length of Runs	Filters	Rotation	Last Serviced	Last Serviced By
1	1	1	Approx. 15'	8	3 mo.	Nov 2015	AAA

Qty	Description	Unit Price (ea)	Line Total
4	Commercial Exhaust Hood Cleaning (Quarterly) Clean and degrease PCU, Duct, Canopy and Filters (Including washable baffles within the PCU) Replace filters in PCU that require replacement.	\$450.00	\$1800.00
2	Fire Suppression System Test (Bi-Annually) Test and maintenance Fire Suppression System, replace fusible links and foils	\$125.00	\$250.00
1	Addition cleaning of duct that runs from PCU to the Common Duct Remove grease and check for leaks. (Quote on repair of leaks when located.)	\$400.00	\$400.00
1	Emergency Lights / Extinguishers Emergency Light System and Battery Test Fire Extinguisher Cylinder and Function Test	\$20.00 \$10.00	\$20.00 \$10.00
Subtotal			\$2480.00
Truck / Fuel Surcharge			INC
GST			\$124.00
Total			\$2604.00

Additional Information:
- Price for Replacement Filters on separate quote.
- Belt BX32 x 2 to be replaced annually \$22.00ea
- Price does not include parts required to repair units.

INSTALLATION BY OTHERS

Field notes: Installation, ductwork, patching, all electrical field wiring, start-up & balance, gas or electric shutdown for fire system hook-up, **fire system hook-up, fire system chemical agent, NO2 cartridge, field piping, detection and pull station line(s), tests and permits.**

Note: Customer is responsible for additional labor charges as a result of cooking equipment layout changes after the release of the order, union labor or prevailing wage charges, or additional trips by fire system distributor caused by jobsite delays, permits, fees or test required by local authority. Submittal will specify applicable testing and approval agencies. **The fire suppression system final hook up is not included on this quote. The final hook up usually consists of, but is not limited to, the chemical agent, Wet chemical cylinder, field piping/re-piping, detection and pull station line(s), tests, and permits.** Hook up for the fire system must be performed by an Authorized Distributor. If not installed by an Authorized Distributor, then the warranty on this product will be voided.

Grease Ducks Ltd. requirement for all field hook ups: All fire system detection conduit must be half inch EMT. All conduit fittings must be compression type and fully tightened. All conduit ends must be reamed and deburred and blown clear of debris prior to assembly. All conduit must be fully and robustly supported to avoid accidental fire system discharge.

Ventilation Direct product must be installed in accordance with installation instructions provided with equipment or available on our web site at www.greaseducks.com.

SHIPPING

Freight includes one shipment only, delivered to the job site address listed on this proposal. Customer is responsible for freight charges on any items shipped early. This is an estimated freight charge and is subject to change based on current freight costs when the job is released for production.

APPROVAL

The above prices, specifications, and conditions are satisfactory and are hereby accepted. You are authorized to perform the work specified. Receipt of the Grease Ducks Ltd. Terms & Conditions are hereby acknowledged and by signature hereto, we agree to said Terms & Conditions. Payment will be made in accordance with authorized agreement. Please note, proposal may be withdrawn by Grease Ducks Ltd. if not accepted within 30 days.

Authorized Signature

Date

Signature

Date

We accept MasterCard®, VISA® cards for immediate credit approval and expedited order processing.

Thank-you for the opportunity to serve you!