

DEDICATED POWER SUPPLY
MARVEL UV BALLAST
120/1/60- 20A



FIELD WIRING BY E.C.

[illegible]


CFM = 4000
COEF = 3698
T.A.B. = 1.088

THIS DRAWING MUST BE CHECKED, SIGNED AND RETURNED TO THE APPROPRIATE FACTORY.
PLEASE VERIFY THE FOLLOWING:

1. ALL DIMENSIONAL INFORMATION, MOUNTING POSITIONS AND CLEARANCES.
2. THE LOCATION AND TYPE OF COOKING EQUIPMENT.

NOTE: TO APPROVER

ANY CHANGES IN COOKING EQUIPMENT SUCH AS INCREASED ENERGY INPUTS OR EQUIPMENT POSITION MAY AFFECT EXHAUST AIRFLOW. HALTON, MUST BE NOTIFIED IF ANY OF THESE CHANGES OCCUR. A RECALCULATION EXHAUST AIRFLOW MAY BE REQUIRED.



MAIL APPROVED DRAWINGS TO APPROPRIATE FACTORY BELOW:	WEBSITE: WWW.HALTONCOMPANY.COM
--	---

HALTON CO. (CANADA)

PROJECT: PACIFIC CENTRE
EL ALAMO WORK

PROJECT:	PACIFIC CENTRE FLAMING WOK	LOCATION:	VANCOUVER BC
----------	-------------------------------	-----------	--------------

PROJECT:	PACIFIC FLAMING	LOCATION:		DRAWN BY:		SCALE:	NOT	CONSULTANT:	
DRAWING TITLE:									
M.A.R.V.E.L. S									
DRAWING No.:		C17-0							
REV. NO.:		1		SHEET		NO.:			

M.A.R.V.E.L. SYSTEM	
DRAWING No.: C17-005	
REV. NO.: 1	SHEET NO.: 3A of 3

M.A.R.V.E.L. SYSTEM	
DRAWING No.: C17-005	
REV. NO.: 1	SHEET NO.: 3A of 3