



SURREY FIRE SERVICE**Occupancy Inspection Report****Send To: Manager of Building Division- Planning & Dev. Dept****Inspection Type:**☐ Daycare / CCA☐ 10% Fire Alarm Test☐ Group☒ Trip TestAddress: 9627 128 Street Date: Aug 31, 2017Name of Building / Business: Sinbad Mediterranean GrillBuilding Permit # 16-38731

Above listed inspection type is:

910 APPROVED**910 NOT APPROVED**

Radio Amplification: Y/N (circle)

Observed deficiencies:

No audible device installed. Install device
in conformance with BC Building Code.

Inspector's Name Ben Wilson (Print) Telephone: 604 543 6768

White copy: Building Division Yellow copy: Fire Prevention Division Last copy: Contractor