

**SURREY FIRE SERVICE**  
**ORDER TO COMPLY**

(The City of Surrey under the Fire Services Act, being Chapter 144, RSBC 1996 and the Regulations Thereto.)  
Fire Prevention: 543-6780 Fax: 594-1237  
8767 132 Street, Surrey, B.C. V3W 4P1

2020/04/08

INSPECTION DATE YY/MM/DD

ADDRESS: 103-5717 152 ST. UNIT: \_\_\_\_\_

BUSINESS NAME: Pizza Pizza

OWNER or OCCUPIER NAME: \_\_\_\_\_

Inspected By: 6-3

Inspection Type: ROI

Inspection Time: \_\_\_\_\_ : \_\_\_\_\_

The Premise has been inspected for fire safety deficiencies pertaining to the following items:

ITEM	CORRECTIVE ACTION
1.	<u>COMMERCIAL KITCHEN HOODS ARE TO BE CLEANED AT <u>MINIMUM</u> ANNUALLY BY ASTABC CERTIFIED DUCT CLEANER</u>
2.	<u>KITCHEN SUPPRESSION SYSTEM TO BE SERVICED Bi-Annually - just PASSED DUE</u>
<u>* 21 Days to Comply.</u>	
<u>778-846-0863</u>	
<u>jason.stefan@surrey.ca</u>	
<u>OK / FOL</u> _____ / <u>NO ACCESS</u> _____	
<u>RECIPIENT (PRINT NAME)</u> _____	

*This report is not a representation that the premises are safe, but a record of violations observed during the inspection. Recorded violations must be corrected immediately. Pursuant to Surrey By-law # 10771 a fee will be charged for each re-inspection required.*

*If violations noted are ONLY one or more of the following, fax or email confirmation showing work has been completed to eliminate a re-inspection and associated fee.*

**206 Exit Signs and Lights**  
**207 Emergency Light Servicing**  
**401 Electrical Panel Minor**  
**501 Portable Extinguishers**  
**502 Servicing Extinguishers**

**542A Fire Safety Plans - Updated**  
**600 Hydrant Servicing**

**Email: [fireprevention@surrey.ca](mailto:fireprevention@surrey.ca)**  
**Fax: 604-594-1237**