



DISTRICT OF NORTH VANCOUVER

FIRE AND RESCUE SERVICES

FIRE SAFETY INSPECTION REPORT

BUSINESS NAME: Maplewood Tap House (formerly Narrows Pu)
 ADDRESS: 1970 Spicer Road. Page 1 of 2

DATE: 11/06/2017
 CONTACT: Jason Baroni

A fire safety inspection was done at the property described above.

The following conditions were noted and require correction immediately.

Actions Required: Please see violations and comments below.

Status:

| | |
|--|----------------|
| 1 BCFC 2.6.1.9.(2) Exhaust and fire protection systems shall be inspected and maintained as per NFPA 96. | UNSATISFACTORY |
| 2 BCFC 2.2.1.2.(1) Repair fire separation so integrity of fire separation is maintained. | UNSATISFACTORY |
| 3 BCFC 6.5.1.6.(2)(b) Emergency lights require annual testing. | UNSATISFACTORY |
| 4 BCFC 2.7.1.6.(1) Means of egress shall be maintained in good repair and free of obstructions. | UNSATISFACTORY |
| 5 NFPA 10-7.1.2.1 Fire extinguishers require annual servicing. | UNSATISFACTORY |
| 6 BCFC 2.8.1.1.(1) Fire Safety Plan required. | UNSATISFACTORY |
| 7 BCFC 2.8.2.7.(1) Emergency Procedures to be posted. | UNSATISFACTORY |

Comments:

1. CEASE & DESIST ALL COOKING ACTIVITY until all deficiencies are corrected on the commercial cooking system. Please call Building Inspector Gordon Postle before doing any work. Telephone 604-990-2251.
2. Repair all holes in drywall fire separations - exit hallways, ceilings, service rooms.
3. Repair emergency light unit in the electrical room.
4. Remove table from upper exterior exit stairs.
5. Fire extinguisher behind upper bar requires service and tag.
6. Update fire safety plan to reflect new ownership.
7. Post Instructions to Occupants,

You are hereby notified that the above conditions shall be corrected immediately ! Failure to correct the above noted violations could render the owner or occupier liable to penalties provided for under The District of North Vancouver Bylaws and/or regulations pursuant to the Fire Services Act.

Note: 2012 BC Fire Code Div C 2.2.1.1.(1) "Unless otherwise specified, the owner or the owner's authorized agent shall be responsible for carrying out the provisions of this code."

Received By:

Title: Business Owner

Issued By:

Title: Kim Saulnier, Inspector

Phone: 604-990-3698