



"serving our city with EXCEL-lence"

Mailing Address: Branch Office:
6215 McKee Street #107-418 E. Kent Ave S.
Burnaby, BC V5J 2V8 Vancouver, BC V5X 2X7

Tel: 604-312-9838
 Fax: 1-866-366-9535 (toll free)
 Email: excelfireprotection@gmail.com
 Web: www.excelfire.ca

FIRE SUPPRESSION SYSTEM REPORT (p1 of 2)

Date on Site: <i>May 21, 2015</i>	Purchase Order: <i>City Fire - Randal</i>	Client ID: <i>A4987659</i>
Client Name: <i>Agra Sweets</i>		Location:
Address: <i>7585 - 6th St.</i>		City: <i>Burnaby</i>
Postal Code: <i>V3N 3M4</i>	Phone: <i>604-526-7879</i>	Fax:
Site Contact: <i>Jaipaul</i>	Mobile: <i>778-245-0909</i>	Email:

Service Type: <i>Semi-annual</i>		System Type: <i>Wet chemical</i>		Location of System: <i>Kitchen</i>		Qty of Cylinders: <i>1</i>
System Manufacturer: <i>Range Guard</i>	Cylinder Model(s): <i>RG-4GT (not UL300)</i>		MFG / Hydro Date: <i>11-1995</i>	Control Head Type: <i>Mechanical</i>	Quantity of Microswitch(s): <i>-</i>	
Fuel Shut Down: <input type="checkbox"/> Solenoid Gas Valve <input checked="" type="checkbox"/> Mechanical Gas Valve	Valve Size: <i>1-1/4"</i>	Electrical Appliances: <input type="checkbox"/> Electrically Powered <input type="checkbox"/> Electrically Controlled	Plenum Size: <i>10 ft + 4 ft extension</i>	Duct Size: <i>16" x 16" + <50"</i>	Hood Type: <i>Air filter</i>	
Fuse Link Detector Type: <i>BTBS</i>	360° Qty: <i>1</i>	450° Qty:	500° Qty: <i>3</i>	Other (specify):		
Appliances:	Deep Fryer	Deep Fryer	Tandoor	Burner Range	Pot Burners	
Quantity:	<i>1</i>	<i>1</i>	<i>1</i>	<i>1 x 6-Burner</i>	<i>3 x 1-burner</i>	
Size:	<i>Not used</i>	<i>16"</i>	<i>-</i>	<i>36"</i>	<i>< 28"</i>	

		Yes	No	N/A	Attn Req			Yes	No	N/A	Attn Req
1	Fire system installed to ULC/ORD-C 1254.6-1995 and manufacturer standards		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		
2	All fire system penetrations into hood/duct through ULC-listed seal device (eg. Quik Seal)	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
3	Absence of open holes in hood canopy	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
4	Piping and conduit are securely bracketed	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
5	All appliances, ducts, & plenum covered by correct nozzle(s)		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		
6	All protective caps/foil seals for nozzles in place	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
7	All appliances & ducts have proper and adequate detection coverage	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
8	Mechanical fuse link detector(s) replaced	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
9	Proper cable tension & travel. Nuts and S-hooks properly installed	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
10	System and control head operates correctly	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
11	Proper manual pull/remote pull operation and location	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
12	Proper cylinder pressure to be in correct range: PSI → <i>175</i>	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
13	Proper control head cartridge weight: Year → <i>gr</i> →			<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		
14	Fuel (gas/electric) to appliances shuts-down upon fire suppression system activation	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		
15	Electrically operated devices shuts-down under hood upon fire suppression system activation			<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		
16	Owners manual/decals (pull station, fan warning) onsite	<input checked="" type="checkbox"/>							<input checked="" type="checkbox"/>		

Portable Fire Extinguisher Inventory

Qty	Type	Location	Service Due
		<i>- serviced by City Fire</i>	

Contact For Fire Alarm: Monitoring Phone and Account: Overall Condition of Hood/Ducts: Last Professional Hood Clean Date:
OK *Dec 2014 (Comm. Vent)*

Comments:

- PLEASE REFER TO FOLLOWING 2ND PAGE FOR COMMENTS

Next Service Due Date: Best Time and Day for Service: Staff In At: Store Hours:
ASAP

Information stated on this form are correct at the time and location of inspection. All equipment have been tested in conformation to applicable codes and/or manufacturers requirements and at this time, was left in operational condition upon completion of this inspection except as noted in comments

Technician: *E.C. & H.C.* ASTTBC No: *FP0859* Date: *May 21, 2015* Time: *8:52am* Authorized By:



"serving our city with EXCEL-lence"

Mailing Address:
6215 McKee Street
Burnaby, BC V5J 2V8

Branch Office:
#107-418 E. Kent Ave S.
Vancouver, BC V5X 2X7

Tel: 604-312-9838
 Fax: 1-866-366-9535 (toll free)
 Email: excelfireprotection@gmail.com
 Web: www.excelfire.ca

FIRE SUPPRESSION SYSTEM REPORT (p2 of 2)

Date on Site: <i>May 21, 2015</i>	Purchase Order: <i>City Fire - Randal</i>	Client ID: <i>A4987659</i>
Client Name: <i>Agra Sweets</i>		Location:
Address: <i>7585 – 6th St.</i>		City: <i>Burnaby</i>
Postal Code: <i>V3N 3M4</i>	Phone: <i>604-526-7879</i>	Fax:
Site Contact: <i>Jaipaul</i>	Mobile: <i>778-245-0909</i>	Email:

Comments Continued:

[1] – System cylinder is not UL300 certified. Require to upgrade to a UL300 certified cylinder. Also, cylinder date (1995) is OVERDUE for hydrostatic test replacement.

[5] – Nozzles and piping need to be reworked. Appliances have incorrect nozzles and/or incorrect height to appliance. Also, the 2 duct nozzles should be upgraded to an up-up position in left hood.

An unauthorized extension hood has been added to the right side with pot burners underneath. Any changes to the ventilation system requires to be engineered and drawings submitted to the City of Burnaby for permits and approval. As it stands right now, there is absolutely no protection and coverage of this new addition (no nozzles in plenum, exhaust duct, or surface appliance coverage). In addition, there is a sizeable open air gap between the original hood and the new hood addition. Lastly, the contractors that installed this new hood addition had just cut open a hole in the plenum area to work around the detection conduit from the fire system. Please note that hoods require to be liquid tight for fire containment.

ATTENTION REQUIRED ASAP

[10] - Advise to have control head upgraded to new UCH control system. Existing mechanical control box no longer supported by manufacturer and there are no parts available for repairs or replacement. If there are any failures with the old control box, this may affect the operation of the fire suppression system and/or the operation of your kitchen for cooking.

[18, 19] – Recommend local bell for audible and interlock canopy lighting to shut-off upon fire system activation.

Technician: <i>E.C. & H.C.</i>	ASTTBC No: <i>FP0859</i>	Date: <i>May 21, 2015</i>	Time: <i>8:52am</i>	Authorized By:
---------------------------------------	-----------------------------	------------------------------	------------------------	----------------