



# Surrey Fire Service

## Order To Comply

(The City of Surrey under the Fire Services Act,  
being Chapter 144, RSBC 1996 and the  
Regulations Thereto.)

8767 132nd Street, Surrey, BC V3W 4P1  
Phone (604) 543 6780 Fax (604) 594 1237

2021-1-21 8:09:58 AM

## Inspection/Violation Report

Inspector: **Geoff McIntyre**

Next Inspection:

Inspection Class: **ROI - Routine Inspection 730**

Date of Inspection: **2021-1-19**

Building Name: **UNION LATINO'S FOOD**

Address: **13569 105A AVE**

Station: **[None selected]**

Reinspection:

Inspected by Shift: **[None selected]**

Inspection Result: **Pending**

## Inspection Items

Item: **207 Emergency Lighting Surrey**

Status: **Unsatisfactory**

Notes: Emergency lighting requires service and tag

Item: **309 Kitchen Ext. (6 months)**

Status: **Unsatisfactory**

Notes: \*\*\*Mount K Class extinguisher in easily accessible location.

Item: **502 Servicing Extinguishers Surrey**

Status: **Unsatisfactory**

Notes: Fire Extinguisher Servicing (B.C.F.C.)

Violation: Portable extinguisher(s) have not been serviced. In accordance with the B.C. Fire Code, fire extinguishers must be serviced every 12 months (annually).

Requirement: Portable extinguisher(s) are required to be inspected and serviced annually by a qualified technician.

□

Item: **320 Special Extinguish System**

Status: **Unsatisfactory**

Notes: Perform inspection, testing and maintenance in accordance with the BC Fire Code

\*\*\*Service due for kitchen suppression system.

Received By:  

---

**This report is not a representation that the premises are safe but a record of violations observed during the inspection. Recorded violations must be corrected immediately. Pursuant to Surrey By-law #10771 a fee will be charged for each re-inspection required.**

**If violations noted are ONLY one or more of the following fax or email confirmation showing work has been completed to eliminate a re-inspection and associated fee.**

**206 Exit Signs and Lights**

**600 Hydrant Servicing**

**207 Emergency Light Servicing**

**Email: fireprevention@surrey.ca**

**401 Electrical Panel Minor**

**Fax: 604-594-1237**

**501 Portable Extinguishers**

**502 Servicing Extinguishers**

**542A Fire Safety Plans - Updated**