



John McKearney, General Manager/Fire Chief
900 Heatley Avenue, Vancouver, BC

Vancouver Fire & Rescue Services
Fire Prevention Division
#306-456 W. Broadway, Vancouver, BC

ORDER

(PURSUANT TO VANCOUVER FIRE BY-LAW NO. 11312)

Date: January 17, 2017

TO: BHULLAR HOLDINGS LTD
18-6828 128 ST
SURREY BC
V3W 4C9

(Name, Mailing address and Postal Code)

The premises ☐ Owned ☐ by you to wit,
(Owned/Occupied)

Limited Service Food Establishment
(Type of Occupancy)

located at 1346 Burrard Street

(Street Address)

Vancouver, B.C., legally known as

LOT 6 PLAN VAS1182
DISTRICT LOT 5 41 NEW
WESTMINSTER UNDIV
6666/1000 000 SHARE IN COM
PROP THEREIN.

Inspected on the 17 day of January 2017.

(Legal Description)

THE INSPECTION REVEALED:

1. Cooking, causing grease laden vapors, without approved fire suppression system.
2. Self-contained deep fryer unit not serviced by a ASTTBC Technician; and not used as a complete assembly (deep fryer door has been removed)
3. Kitchen exhaust system is non-compliant.
4. Building sprinkler system is obstructed with the non-compliant hood exhaust

Based upon the above, it is the opinion of the Fire Chief a condition exists at
Vancouver, B.C., which endangers life and poses a risk of injury or loss by fire.

1346 Burrard Street

(Street Address)

THEREFORE, pursuant to the authority vested in me in accordance with Vancouver Fire By-Law 11312, Division C, Sentence 1.4.3.1.(1), you are HEREBY ORDERED TO:

1. Cease and desist cooking causing grease laden vapours until a complete NFPA 96 compliant fire suppression system is installed. **VFBL Div. B 2.6.1.9.(2)**
2. Have self-contained deep fryer unit serviced by an ASTTBC Qualified Technician **VFBL Div. B 2.6.1.9.(2)**
3. Provide engineers report for kitchen exhaust system or apply for a new permit to install a new kitchen exhaust system. **VFBL Div. B 2.6.1.9.(2)**
4. Remove or change kitchen exhaust in a manner so that the sprinklers are not obstructed. **VFBL Div. B 6.4.1.1.(1)**

This Order is to be complied with on or before:

Item 1 Immediately; and items 2 - 4 by January 31 2017 17:00
Hours

An inspection to determine compliance with this order will be conducted on: **February 1, 2017 15:00 Hours**

This order does not relieve the owner or occupier of the obligation to comply with all City of Vancouver by-laws, including the requirement to obtain a permit or permits to undertake the work. For Permit Information Contact: Developments and Building Services Centre, Main Floor, 515 West 10th Ave. Phone: 604-873-7611

(Signature of Recipient)

FPI Patrick Grimminck

(Print name and Tel. # of recipient)

Rob Renning

(Date Delivered)

FPI {Inspector Name}

(AGM / Deputy Chief Fire Prevention) **print name**

Signature of (AGM / Deputy Chief Fire Prevention)