



1725 Broadway Street, Port Coquitlam BC, Canada, V3C 2M9

Tel 604.927.5466 • Fax 604.927.5406

fire@portcoquitlam.ca



**Date of Letter:** 01/26/2017

**Date of Inspection:** 01/26/2017

**Property Name:** Kamizato Japanese Restaurant

**Attention:** Business Owner

**Property Address:** 2105 2850 SHAUGHNESSY ST PORT COQUITLAM V3C6K5

**Property Owner:** 1510060 Ontario Inc. c/o Terracap Management Inc.

The deficiencies listed below were noted during an inspection of the above noted property on 01/26/2017. In order to maintain a fire safe environment, these observed violation(s) must be corrected immediately.

Based on the conduct of your business activities a commercial cooking unit with suppression and venting is required.

A certified portable unit may be acceptable

This report is not a representation that the premises are safe, and is merely a record of observed violations. The Fire Department conducts a variety of inspections, and the nature of those inspection varies significantly. Pursuant to Port Coquitlam Bylaw #3880, if the Order for Deficiencies has not been complied with upon the re-inspection, a fee will be charged for the re-inspection and each additional re-inspection if required.

**If you have any questions or need information please contact me at 604-927-5464.** Failure to conform is an infraction of the City Fire Protective Services Bylaw, BC Fire Services Act or the BC Fire Code and is liable to the penalties and/or conditions in those regulations.

Yours Truly,

Captain Stewart Novak  
Local Assistant Fire Commissioner