



Surrey Fire Service

Order To Comply

(The City of Surrey under the Fire Services Act,
being Chapter 144, RSBC 1996 and the
Regulations Thereto.)

8767 132nd Street, Surrey, BC V3W 4P1
Phone (604) 543 6780 Fax (604) 594 1237

2020-7-21 11:16:21 AM

Inspection/Violation Report

Inspector: **S. Paul Dornian**

Next Inspection: **2020-8-20**

Inspection Class: **REV - RE-VISIT**

Date of Inspection: **2020-7-21**

Building Name: **OKONOMIYAKI PON**

Address: **110 2950 KING GEORGE BLVD**

Station: **[None selected]**

Reinspection:

Inspected by Shift: **[None selected]**

Inspection Result: **Follow-Up**

Inspection Items

Item: **206 Exit Signs & Lights Surrey**

Status: **Unsatisfactory**

Notes: Have your exit signs serviced

Item: **207 Emergency Lighting Surrey**

Status: **Unsatisfactory**

Notes: Emergency lighting requires service and tag

Item: **309 Kitchen Ext. (6 months)**

Status: **Unsatisfactory**

Notes: Extinguishing system shall be serviced every 6 months

Item: **320 Special Extinguish System**

Status: **Unsatisfactory**

Notes: Perform inspection, testing and maintenance in accordance with the BC Fire Code

Item: **502 Servicing Extinguishers Surrey**

Status: **Unsatisfactory**

Notes: Fire Extinguisher Servicing (B.C.F.C.)

Violation: Portable extinguisher(s) have not been serviced. In accordance with the B.C. Fire Code, fire extinguishers must be serviced every 12 months (annually).

Requirement: Portable extinguisher(s) are required to be inspected and serviced annually by a qualified technician.

Received By:

This report is not a representation that the premises are safe but a record of violations observed during the inspection. Recorded violations must be corrected immediately. Pursuant to Surrey By-law #10771 a fee will be charged for each re-inspection required.

If violations noted are ONLY one or more of the following fax or email confirmation showing work has been completed to eliminate a re-inspection and associated fee.

206 Exit Signs and Lights

600 Hydrant Servicing

207 Emergency Light Servicing

Email: fireprevention@surrey.ca

401 Electrical Panel Minor

Fax: 604-594-1237

501 Portable Extinguishers

502 Servicing Extinguishers

542A Fire Safety Plans - Updated