



DISTRICT OF NORTH VANCOUVER

FIRE AND RESCUE SERVICES

FIRE SAFETY INSPECTION REPORT

BUSINESS NAME: Gilaneh Grillhouse
 ADDRESS: 222 Pemberton Ave

DATE: 04/29/2017
 CONTACT: Shahrani Pouriae

A fire safety inspection was done at the property described above.
 The following conditions were noted and require correction immediately.

Actions Required: Please see violations and comments below.

Status:

1 BCFC 6.3.1.2.(1) Annual fire alarm servicing and testing required.	<u>UNSATISFACTORY</u>
2 BCFC 6.5.1.6.(2)(b) Emergency lights require annual testing.	<u>UNSATISFACTORY</u>
3 BCFC 2.7.1.6.(1) Means of egress shall be maintained in good repair and free of obstructions.	<u>UNSATISFACTORY</u>
4 BCFC 2.6.1.9.(2) Exhaust and fire protection systems shall be inspected and maintained as per NFPA 96.	<u>UNSATISFACTORY</u>
5 CSA 4-010 Extension cords shall not be used in place of fixed wiring.	<u>UNSATISFACTORY</u>
6 NFPA 10-8.4.1 Repair / replace damaged extinguishers.	<u>UNSATISFACTORY</u>
7 BCFC 2.7.3.1.(2) Exit lighting and exit signs shall be illuminated.	<u>UNSATISFACTORY</u>

Comments:

1. Fire alarm requires testing
2. Emergency lights require annual testing
3. Clear all obstructions from second floor east side exit stairwell (machines and product)
4. Commercial kitchen hood & wet chemical system require semi annual cleaning & testing
5. Discontinue use of extension cords (second floor hall)
6. Replace or repair fire extinguishers due for 6 year hydro test
7. Repairs required to 2nd floor emergency lights (low battery) & repair broken exits signs

You are hereby notified that the above conditions shall be corrected **within 14 days**. Failure to correct the above noted violations could render the owner or occupier liable to penalties provided for under The District of North Vancouver Bylaws and/or regulations pursuant to the Fire Services Act.

Note: 2012 BC Fire Code Div C 2.2.1.1.(1) "Unless otherwise specified, the owner or the owner's authorized agent shall be responsible for carrying out the provisions of this code."

Received By:

MET SHAHRANI
ON SITE

Title: Business Owner

Issued By:

Title: Howard Weatherstone, Lieutenant

Phone: 604-990-3673