

SURREY FIRE SERVICE
ORDER TO COMPLY

(The City of Surrey under the Fire Services Act, being
Chapter 144, RSBC 1996 and the Regulations Thereto.)
Fire Prevention: 543-6780 Fax: 594-1237
8767 132 Street, Surrey, B.C. V3W 4P1

18/02/18

INSPECTION DATE YY/MM/DD

ADDRESS: 10153 - KGH UNIT: 709

BUSINESS NAME: KENTUCKY FRIED CHICKEN

OWNER or OCCUPIER NAME: _____

Inspected By: 142729

Inspection Type: RO

Inspection Time: 10 : 00

The Premise has been inspected for fire safety deficiencies pertaining to the following items:

| ITEM | CORRECTIVE ACTION |
|------------------------|--|
| 207 | REPAIR EMERGENCY LIGHT ABOVE REAR ENTRANCE DOOR |
| 320 | SERVICE AND REPAIR KITCHEN FIXED EXTINGUISHING SYSTEM (FP 1417) TAGS DEFICIENT (10 BUSINESS DAYS). |
| 21 DAYS TO COMPLY. | |
| OK / FOL | / NO ACCESS / |
| RECIPIENT (PRINT NAME) | |
| <u>RAMEN BRAR.</u> | |

This report is not a representation that the premises are safe but a record of violations observed during the inspection. Recorded violations must be corrected immediately. Pursuant to Surrey By-law # 10771 a fee will be charged for each re-inspection required.

If violations noted are ONLY one or more of the following fax or email confirmation showing work has been completed to eliminate a re-inspection and associated fee.

206 Exit Signs and Lights

207 Emergency Light Servicing

501 Portable Extinguishers

502 Servicing Extinguishers

542A Fire Safety Plans - Updated

600 Hydrant Servicing

Email: fireprevention@surrey.ca

Fax: 604-594-1237

White Copy - Owner/Occupier Yellow Copy - Fire Service

EASFU Forms\fire dept. forms\Form90 Fire Safety Report 12 11 22