



FIRE & RESCUE SERVICES  
NOTICE OF VIOLATION  
Restaurants

Firehall Office Use only	
<input type="checkbox"/> Routine Inspection	<input type="checkbox"/> Incident
<input type="checkbox"/> Entered into FDM:	Date: _____

Date: Aug 23/17 Time: 1445  
Address of Violation: 138 Davie st Business/Name: Hojin Sushi  
Business Owner: Roger Teo Phone #: 604 688 8808 Fax #: \_\_\_\_\_  
Person Notice Given To: Fred Mak Title: Manager Phone#: 604 688 8808  
Receipt of Notice: [Signature] (signature)

ITEM	CODE	Vancouver Fire By-Law Violations - FOR IMMEDIATE COMPLIANCE	
	6.1.1.5.(1) Div B	A service agent shall test, inspect and maintain a fire protection system, fire pump, emergency power or a commercial kitchen exhaust system.	
	6.1.1.5.(4) Div B	All Fire Protection Equipment referred to in Sentence (1) shall have a tag securely attached to show the maintenance date, the name and signature of the service agent, and if applicable, addition work required.	
	6.1.1.5.(2) Div B	<input checked="" type="checkbox"/> Have PORTABLE FIRE EXTINGUISHERS serviced by ASTTBC qualified technician, and service tag securely affixed to serviced equipment.	
	6.1.1.5.(1) Div B	<input checked="" type="checkbox"/> Have KITCHEN SUPPRESSION SYSTEM serviced by ASTTBC qualified technician and service tag securely affixed to serviced equipment.	
	6.1.1.5.(1) Div B	<input checked="" type="checkbox"/> Have COMMERCIAL HOOD EXHAUST SYSTEM serviced by ASTTBC qualified technician and service tag securely affixed to serviced equipment.	
	6.1.1.5.(1) Div B	<input type="checkbox"/> Have EMERGENCY LIGHTING SYSTEMS serviced by ASTTBC qualified technician, and service tag securely affixed to serviced equipment.	
	6.1.1.5.(1) Div B	<input type="checkbox"/> Have FIRE ALARM SYSTEM serviced by ASTTBC qualified technician and service tag securely affixed to serviced equipment.	
	2.1.5.1.(2) Div B	<input type="checkbox"/> Provide "K" Class Portable Fire Extinguisher.	
	2.1.5.1.(2) Div B	<input type="checkbox"/> Provide 5lbs "ABC" Class Portable Fire Extinguisher.	
	2.7.1.6.(1) Div B	<input type="checkbox"/> Ensure all means of egress and access to exits are clear and free of any obstructions at all times.	
	2.6.1.9.(1) Div B	<input type="checkbox"/> Provide NFPA 96 commercial exhaust system and fire protection system.	
		<input type="checkbox"/> Additional info provided to occupier.	
	2.7.1.4.(1) Div B	<input type="checkbox"/> Have Occupant Load certificate posted.	
		<input type="checkbox"/> Have K3 form completed by occupier, and signage posted	

This Notice of Violation makes you legally responsible for any consequences arising from this matter. A re-inspection service charge of \$200.00 (or as per the current Vancouver Fire By-law fee schedule) for each hour or part thereof (plus G.S.T.) will be assessed for each re-inspection, until the violations noted have been corrected. Failure to comply with the above instructions may result in legal action against the Owner/Occupier.

IMPORTANT INFORMATION  
Please have this translated

RENSEIGNEMENTS IMPORTANTS  
Prière de les faire traduire

重要資料  
請使人為你翻譯

अग्नी नटवरी  
विश्व बरहे विमो वीरो दिम रा वीरों बरवरी

CHỈ DẪN QUAN TRỌNG  
Xin nhó người dịch hế

INFORMACIÓN IMPORTANTE  
Busque alguien que le traduzca

A fire inspection of the above premises disclosed violations which may constitute a hazard to life or property in the event of fire and must be corrected.

SAP #: \_\_\_\_\_ Hall #: 50 Shift: \_\_\_\_\_

FOR RE-INSPECTION APPOINTMENT DIAL 311