CITY OF VANCOUVER

ORDER

(PURSUANT TO VANCOUVER FIRE BY-LAW NO. 11212)

Date: January 17, 2017

TO: SHULZ/FHOLDINGS LTD
(Name, 123 St)

VANCOUVER
(Name, Mailing address and Postal Code)

The premises Owned by you to wit,
(Owned/Occupied)

located at 1346 Burrard Street
(Street Address)

Vancouver, B.C., legally known as

LOT 5 PLAN VAS1182
DISTRICT LOT 6 41 NEW
WESTMINSTER (HOW
[illegible] 000 SHARE IN COM
PROP THEREIN

Inspected on the 17 day of January 2017.

THE INSPECTION REVEALED:

1. Cooking equipment grease laden vapors without approved fire suppression system.
2. Self-contained deep fryer unit not serviced by a AST TPC Technician, and not used as a cooking appliance.
3. Kitchen exhaust system is non-compliant.

Found upon the above, it is the opinion of the Fire Chief a condition exists at 1346 Burrard Street Vancouver, B.C., which endangers life and poses a risk of injury or loss by fire.

THEREFORE, pursuant to the authority vested in me in accordance with Vancouver Fire By-Law 11212, Division C, Sections 1.4.3.1 (1), you are HEREBY DIRECTED TO:

1. Cease and desist cooking deep fryer under vapors until a complete HFDA 99 compliant fire suppression system is installed. **VFR, Div. B 2.2.1.4.(2)**
2. Have self-contained deep fryer unit serviced by an AST TPC Certified Technician **VFR, Div. B 2.4.1.5.(1)**
3. Provide engineers report for kitchen exhaust system or apply for a new permit to install a new kitchen exhaust system. **VFR, Div. B 2.6.1.5.(3)**
4. Remove or change kitchen exhaust in a manner so that the opinions are not obstructed. **VFR, Div. B 2.4.1.1.(1)**

This Order is to be complied with on or before:

(Item 1 immediately and Items 2 - 4 by January 31 2017 17:00 Hours)

Failure to comply with this order will be a violation of the Vancouver Fire By-Law.

This order does not relieve the owner or occupier of the obligation to comply with all City of Vancouver by-laws including the requirement to obtain a permit or permits to undertake the work. For Permit Information Centre Development and Building Services, City of Vancouver, 515 West 10th Ave., Phone: 604-873-7611

(Signature of Recipient)

(Print name and Title of Recipient)

Rob Fanning

(Date Delivered)

FPI (Inspector Name)

Rob Fanning, Inspector, Fire Prevention, Print name

Signature of Acting Fire Chief or Deputy Fire Chief

Page 1 of